



BST&G Fire District Fire Prevention Bureau

Private Fire Hydrant – Test and Maintenance Report

Private fire hydrants are required to be inspected annually and flushed annually per
The Ohio Fire Code and NFPA

Business/ Property Information

Inspection Date _____

Facility name: _____

Address: _____

Contact Person _____ Phone _____

Hydrant # _____ Location _____

Hydrant Brand Name _____ 5 inch NST _____ 5 inch Stortz _____

Total number of fire hydrants tested and maintenance performed at this location _____

Report of private fire hydrant service condition: (use 1 form per fire hydrant)

Condition Checked	Status Pass/Fail	Corrective Action
Access to hydrant 36 inch clear space around hydrant		
Painted and reflective stripe (paint missing/ wrong color)		
Hydrant barrel found dry		
Hydrant found free of leaks (visual and sound)		
Hydrant flushed wide open 1 minute		
Outlet threads worn/cross threaded		
Caps and chain in place		
Caps removed and lubricated		
Operation nut (pentagon) worn		
Lubricate stem		
Hydrant barrel left dry		
Hydrant operation after lubrication		

*Private fire hydrants and PIV around the master meter shall be painted DeVoe 9700 Safety Green or approved equal and a 2 inch white reflective band around the flange of the bonnet.

**** Lubrication of private fire hydrants shall be with a food grade lubricant.**

NOTICE TO OWNER: For items noted as failed or needing attention on this report, you are responsible for correcting these items and resubmitting an inspection report when the work is completed and passes inspection.

Owner/ Owner's Representative Signature: _____

Testing Firm: _____ Phone _____

Responsible Person Performing Test

Signature: _____

Print Name: _____

Return this report to **BST&G Fire District Fire Prevention Bureau** Form may be copied as needed